ADDENDUM NO. TWO (2)

TO THE BIDDING DOCUMENTS FOR

Blue Valley School District - 2017 Flooring Replacement - Winter 2016/Spring 2017

ISSUE DATE: 27 October, 2016

Contractors are hereby notified that the Construction Documents on the above-named project, for which bids will be taken 1 November, 2016, are amended as noted below.

This Addendum forms a part of the Contract Documents and consists of (1) page of 8.5 X 11 and NO drawing.

CHANGES TO THE DOCUMENTS – Blue Valley School District – 2017 Flooring Replacement Winter 2016 / Spring 2017

Changes to the SPECIFICATIONS

AD2.1 Section 03536 – Polished Concrete Flooring; SUBSTITUTION: ONFLOOR is not approved equal.

Certified Installers: Treadwell is not approved HiperFloor certified.

AD2.2 Section 03536 – Polished Concrete Flooring;

Modify paragraph 1.4.E to read "wet DCOF minimum of 0.37 tested per ANSI B101.3." Modify paragraph 3.7.C.1 to read "Lumen reading for an average of 55 with a

minimum value of 50."

AD2.3 Section 09705 – Resinous Flooring:

SUBSTITUTION: Bio-flake is not approved equal.

Contractors must acknowledge receipt of this Addendum with bid.

END OF ADDENDUM NO. TWO (2)