

ADDENDUM NUMBER TWO

February 2, 2018

**ROOF REPLACEMENT – 1996 ADDITION
Southeast of Saline K-12 Building
Unified School District 306
5056 E. Highway K4
Gypsum, Kansas 67448**

The following addendum items amend the Drawings, Specifications, and other Project Manual documents prepared by The Ebert Mayo Design Group, Architects & Planning Consultants, 1115 Westport Drive, Manhattan, Kansas 66502.

Planholders shall attach this addendum to their copy of the Project Manual. Bidders shall acknowledge receipt of this addendum on the Proposal Form.

The bid date remains unchanged. Bids will be received in accordance with the Notice to Bidders included in the Project Manual until 12:00 pm, February 8, 2018, at the District Office, 5056 E. Highway K4, Gypsum, Kansas.

1.1 Mechanical Work:

- A. Information: The Owner may modify the required mechanical work by change order after contract award. Bidders are to base their bids on the mechanical scope of work shown in the construction documents.

1.2 Roofing at Flat Insulation Areas:

- A. Addition: Two roof areas, referred to as areas J and L in the roof condition report excerpts after Section 02 4119, will be receiving additional insulation. The new insulation shall be attached to the existing coverboard in area J, and to the existing Tectum in area L. The attachment method and any base sheets shall be as recommended in writing by the manufacturer of the roofing membrane in order to meet the specified performance requirements.

END OF ADDENDUM TWO